

**Hammond Central School District
2024-2025 Capital Outlay Project
Project No. 2024-033**

Addendum No. 2
October 11, 2024

Main Building SED Control No. 51-12-01-04-0-001-020


This addendum is hereby made part of the Contract Documents as though it were originally included therein and must be acknowledged by the bidder in the proper place on the bid form.

Contract Drawings

1. Reference Sheet No. AD100 Demolition Plans:

- A. **ADD** the following to Demolition Notes number 3: "Disconnect of CUV includes proper removal and reinstallation of hot water supply and return piping, controls, electric, etc."

Respectfully submitted,
BCA Architects & Engineers,



Bryan T. Cowell, R.A., LEED Green Associate
Associate Principal/Architect

BTC

I:\Projects\2024-000\2024-033.HammondCSD\Addenda\BID\BID AD2